



# THE KADAPA DISTRICT COOPERATIVE CENTRAL BANK LTD.

R.S.ROAD, KADAPA-516001.

Ph: 08562-245348, 224865, 277788 & 222595 Fax: 08562-224865  
e-mail: ceo\_kdph@apcob.orgurl: <https://www.kadapadccb.in>

Rc.No.IT Section/Quotations /2022-23

Date:01.07.2023

To

The Proprietor,

\_\_\_\_\_

\_\_\_\_\_Pin Code\_\_\_\_\_

## QUATATION

Sir,

Sub: Kadapa DCCB, Head Office Supply and Installation of 10 KVA, 6 KVA of UPS, and 65 Ah and 42 Ah batteries, with a buyback policy – Quotations – Called for

Kindly submit your quotation quoting the rates for the materials noted below subject to the terms and conditions

S.No	Material Specification	Required Quantity	Buyback Quantity	
1	10 KVA ,360 VDC ONLINE UPS SYSTEM CONFIRMS TO IS 16242(PART-1):2014 and IEC 60240-1:2008 WITH IGBT technology pure sine wave output , double conversion with auto and manual static by pass switch three phase input/single phase output	1	0	
2	10 KVA ,240 VDC ONLINE UPS SYSTEM CONFIRMS TO IS 16242(PART-1):2014 and IEC 60240-1:2008 WITH IGBT technology pure sine wave output , double conversion with auto and manual static by pass switch three phase input/single phase output	8	1	
3	6 KVA ,192 VDC ONLINE UPS SYSTEM CONFIRMS TO IS 16242(PART-1):2014 and IEC 60240-1:2008 WITH IGBT technology pure sine wave output , double conversion with auto and manual static by pass switch Single phase input/single phase output	16	5KVA 3KVA	9 15
3	65 Ah	4	88	
4	42 Ah	316	80	

The due date of Receipt of quotations **07.07.2023**

Manager

**Terms & Conditions:**

1. Firm Should Maintained ISO Standard and Certified
2. Quotation should be for free delivery at DCC Bank, Kadapa
3. Prices quoted should be Net and should be remained valued for a minimum period of one month from the date of quotation
4. Manufactures name and Country of Origin of Materials should be specified
5. One Unit must be supplied to reach us before due date
6. If GST is to paid extra, should be clearly stated
7. The company should have been established for at least Ten years.